

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7257-0569:112

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector (Single/Multiple)

LISTEE: Gentex, 10985 Chicago Dr., Zeeland MI 49464
Contact: *Keiffer Sestric (616) 392-7195 FAX (616) 392-4219

DESIGN: Models 911, 911T, 913, 913T, 9100, 9103, 9103T and 9100T single station, battery operated, photoelectric type smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 9 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as single station photoelectric smoke detectors for use with Duracell Model MN 1604 or Eveready Model 522 alkaline batteries.

Models 913, 913T, 9103 and 9103T can generate a temporal code pattern fire alarm signal (for evacuation) as required per NFPA 72, 2002 Edition.

Models 911, 911T, 9100 and 9100T are non-temporal and are intended for use in occupancies that do not require total evacuation but perhaps relocation or notification.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

*Rev. 12-09-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division