

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0569:114 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Gentex Corporation, 10985 Chicago Dr., Zeeland MI 49464
Contact: *Keiffer Sestric (616) 392-7195 Fax (616) 392-4219

DESIGN: Strobe Models GXS-2-15, GXS-2-15/75, GXS-4-15, GXS-4-15/75, GXS-4-30, GXS-4-30/75, GXS-4-60, GXS-4-110 and GXS-120-177; AVP-2-15, AVP-2-15/75, AVP-4-15, AVP-4-15/75, AVP-4-30/75, AVP-4-110, AVP-4-110-1, and AVP-120-177. All units may be followed by suffix -C or -W (ceiling or wall mount) and -W or -R (white or red). Models with suffix -Z are synchronized strobe and are intended for connection with the sync module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Candela: -15: 15cd; -15/75: 15cd & 75cd at 0° angle axis
-30/75: 30cd & 75cd at 0° angle axis; -30: 30cd; -60: 60cd
-110: 110cd; -177: 177cd

Electrical: -120: 120 VAC; -4: 21-30 VDC; -2: 10-16 VDC

Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela ratings and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use only.

NOTE: Formerly 7300-0569:114

*Rev. 12-09-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division