

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7135-0569:131

Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Gentex Corporation, 10985 Chicago Dr., Zeeland MI 49464
Contact: Keiffer Sestric (616) 392-7195 FAX (616) 392-4219

DESIGN: Models WGESA24-75, WGESB24-75, WGESG24-75, and WGESR24-75 strobe lights. Units employ a strobe flash tube and electronic trigger circuit mounted on a printed wiring board with a color lenses. All models are rated 75cd on-axis and are intended for indoor or outdoor use. When used outdoors, either Model GOE Weatherproof Enclosure or Model GOELP Low Profile Weatherproof Enclosure must be employed. Unit is for private mode signaling use only. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 16 – 33 VDC
Candela: 75cd

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as strobes for use with separately listed compatible fire alarm control units. Not approved for hearing impaired applications.

09-16-2005 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division