

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7135-0569:133 Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Gentex Corporation, 10985 Chicago Dr., Zeeland MI 49464  
Contact: Keiffer Sestric (616) 392-7195 FAX (616) 392-4219

**DESIGN:** Model GCSA24, GCSB24, GCSG24, and GCSR24 strobe lights. Units employ a strobe flash tube and electronic trigger circuit mounted on a printed wiring board with a color lenses. Unit is intended for indoor use only mounted on the wall or on the ceiling. Unit is for private mode signaling use only. Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 16 – 33 VDC  
Candela: 15cd, 30cd, 60cd, 75cd, 95cd and 115cd Selectable

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as strobes for use with separately listed compatible fire alarm control units. Not approved for hearing impaired applications.

09-16-2005 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires June 30, 2010*

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division