

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7320-0569:140

Page 1 of 1

CATEGORY: Speakers

LISTEE: Gentex Corporation, 10985 Chicago Dr., Zeeland MI 49464
Contact: Keiffer Sestric (616) 392-7195 x 3265 Fax (616) 392-4219

DESIGN: Models SSPK24WLP and SSPK24-15/75WLP speaker strobes. May be followed by suffix – P, -W, or -R (plain, white, or red color). All models are intended for indoor use only and are wall mounted in a listed double-gang backbox. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Speaker	25 Vrms and 70.7 Vrms
Strobe	24 VDC
Flash Rate	60 flashes per minute
Candela	15, 30, 60, 75 & 15/75, 110 for Model SSPK24WLP 15/75 fixed candela for Model SSPK24-15/75WLP

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, ratings, and UL label.

APPROVAL: Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Both models are suitable for the hearing impaired applications. For indoor use only. Refer to manufacturer's Installation Manual for details.

These devices do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

08-24-2007 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division