

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7254-0569:142

Page 1 of 1

**CATEGORY:** Heat Detector (Single/Multiple)

**LISTEE:** Gentex Corp., 10985 Chicago Drive, Zeeland, MI 49464  
Contact: Keiffer Sestric (616) 392-7195 FAX (616) 392-4219  
*Keiffer.Sestric@gentex.com*

**DESIGN:** Models HD135, -220, -223 single and multiple station, 135°F fixed temperature type heat detectors. Model HD135 is 120 VAC while Models HD135-220 and -223 are 220 VAC operated with a 9 VDC non-rechargeable battery backup. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as single/multiple station heat detector. This detector can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to listee's Installation instructions Manual for details.

08-06-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 6, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*