

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 5276-0569:143 Page 1 of 1

CATEGORY: Single/Multi Station Carbon Monoxide Detectors

LISTEE: Gentex Corporation, 10985 Chicago Drive, Zeeland, MI 49464
Contact: Keiffer Sestric Ph: 616-392-7195 Fax 616-392-4219
Keiffer.sestric@gentex.com

DESIGN: Model CO1209 and CO1209F Carbon Monoxide detectors. Refer to Listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, UL labeling, electrical rating, and required WARNINGS label.

APPROVAL: Listed as a wired Carbon Monoxide Detector for residential applications. Refer to manufacturer's installation manual for details.

NOTE: Carbon Monoxide detectors are **not** intended/suitable for fire and smoke detection.

08-06-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division