

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0569:0132

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Gentex Corporation 10985 Chicago Drive, Zeeland, MI 49464
Contact: Keiffer Sestric (616) 392-7195 Fax (616) 392-4219
Email: keiffer.sestric@gentex.com

DESIGN: Model WGECA24-75, WGECA24-75, WGECA24-75 and WGECA24-75 horn/strobe lights. Units employ a strobe flash tube and electronic trigger circuit mounted on a printed wiring board with color lens. Unit is intended for indoor use, or outdoor use when mounted on the wall only. When used outdoors either Model GOE weatherproof enclosure or Model GOELP low profile weatherproof enclosure must be employed. Unit is for private mode signaling use only. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 16 - 33 VDC

Candela: 75cd

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as horn/strobes for use with separately listed compatible fire alarm control units. Not approved for hearing impaired applications.

NOTE:

09-16-2005 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division