

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7257-0569:0138 Page 1 of 1

CATEGORY: 7257 -- SMOKE ALARM-PHOTOELECTRIC TYPE (SINGLE/MULTIPLE)

LISTEE: Gentex Corporation 10985 Chicago Drive, Zeeland, MI 49464
Contact: Keiffer Sestric (616) 392-7195 Fax (616) 392-4219
Email: keiffer.sestric@gentex.com

DESIGN: Models GN-200, GN-203, GN-300 and GN-303 single/multiple station photoelectric smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: GN-200, GN-203 120 VAC
GN-300, GN-303 120 VAC with 9 VDC battery backup

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as AC powered single/multiple station photoelectric smoke detectors with battery backup.

Models GN-203 and GN-303 can generate a distinctive temporal code pattern fire alarm signal (for evacuation) in accordance with NFPA 72, 2002 Edition. Refer to listee's Installation Instructions Manual for details.

Models GN-200 and GN-300 are non-temporal and are intended for use in occupancies that do not require total evacuation but perhaps relocation or notification.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

09-18-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division