

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7320-0569:0141

Page 1 of 1

**CATEGORY:** 7320 -- SPEAKERS

**LISTEE:** Gentex Corporation 10985 Chicago Drive, Zeeland, MI 49464  
Contact: Keiffer Sestric (616) 392-7195 Fax (616) 392-4219  
Email: keiffer.sestric@gentex.com

**DESIGN:** Models WSSPK speaker, WSSPK24-15/75WLP speaker strobes and GBLP backbox.  
Model WSSPK followed by R (red) or W (white). Model WSSPK, followed by A (amber), B (blue), G (green), R (red) indicating, followed by 24-15/75, may be followed by -A (alert), -P (plain), then followed by W (wall) and followed by R (red) or W (white). Suffix WLP indicates wall mount and low profile design. All models are intended for use with Model GBLP backbox for outdoor applications. Strobe is intended for non-fire applications. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Speaker	25 Vrms and 70.7 Vrms
Strobe	24 VDC
Flash Rate	60 flashes per minute
Candela	15/75

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, ratings, and UL label.

**APPROVAL:** Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Model WSSPK24-15/75WLP is NOT suitable for the fire alarm notification for the hearing impaired applications. For indoor and outdoor applications. Refer to manufacturer's Installation Manual for details.

These devices do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

10-06-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*